

# BOROUGH OF WOODLAND PARK

ESTABLISHED 1914

TRACY KALLERT  
MAYOR



OFFICE OF THE MAYOR  
TKALLERT@WPNJ.US

April 20, 2026

Dear Woodland Park Resident,

We hope this letter finds you well.

Enclosed, you will find a letter from the Borough as it relates to a public notification the New Jersey Department of Environmental Protection ("NJDEP") is requiring the Borough to send regarding orthophosphate levels arising out of a test dating back August 6, 2025, and November 19, 2025.

Woodland Park purchases 100 % of their drinking water from the Passaic Valley Water Commission. On March 23, 2026, our licensed water operator was notified about a violation received from the NJDEP regarding two orthophosphate levels that did not meet WQP values at the point where water enters our system when sampling was performed. Typically, the testing laboratory reports any non-compliant results to the municipality so that prompt retesting can be conducted to reduce the likelihood of a violation. Please note all orthophosphate samples throughout our distribution system were compliant with the standard during the same time period. NJDEP requires the municipality to issue the enclosed public notification.

**Please be advised there is not currently nor were there any safety concerns regarding the Borough's drinking water on August 6th and November 19, 2025. It is important to know that orthophosphate is not a contaminant.**

To remedy this situation, the Borough is utilizing a different contact lab that will provide timelier reporting to the Municipality in the event a sample like this occurs again.

This advanced notification will allow us to retest and reduce excursions, which would therefore minimize the likely need for the enclosed PN.

The notice itself is a form letter which must be delivered with little modification. Water systems are only able to revise the "**What is being done?**" section to suit the system's individual situation. Please read this section carefully when you receive the notice as it is the description of our specific situation.

The sections "What should I do?" and "What does this mean?" pertain specifically to lead and copper exposure. However, as is stated in the notice, importantly, the Borough is in full compliance with lead and copper action levels, as per federal regulations established by the U.S. Environmental Protection.

If you have any questions regarding the required Public Notification, corrosion control treatment or water quality issues you are welcome to contact:

Anthony Laguerra or Matthew Mulroony at 973-256-1264.

Tracy Kallert  
Mayor – Woodland Park

Matthew Mulroony  
Superintendent – Department of Public Works

5 BROPHY LANE – WOODLAND PARK, NJ 07424 • WWW.WPNJ.US  
MAYOR'S OFFICE 973.345.8100 x210 • FAX 973.345.8194

# Borough of Woodland Park

Department of Public Works

MATTHEW MULROONY  
Superintendent



Passaic County, NJ  
One Browertown Road  
Woodland Park, NJ 07424  
(973) 256-1264  
Fax: (973) 256-3935  
Email: mmulroony@wpnj.us

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Woodland Park Water Department Fails to Meet Established Water Quality Parameter (WQP) Levels

Our water system recently violated a New Jersey drinking water requirement, as our customers, you have a right to know what happened, what you should do, and what we did to correct this situation.

Our water system has corrosion control treatment installed and receives corrosion control treated water to help prevent lead and/or copper in the pipes from dissolving into the water. The corrosion control treatment was deemed optimized; and therefore, the New Jersey department of Environmental Protection (NJDEP) established optimal Water Quality Parameters (WQP) values, which are values the corrosion control treatment functions most effectively. We monitor for WQP values per federal regulations.

During the 6-month monitoring period, i.e., July 1, 2025 to December 31, 2025 monitoring period, our WQP sample results did not meet the optimal WQP values set by the NJDEP for 14 days, and the water system cannot be below the minimum level(s) or outside the range(s) set by the NJDEP for more than nine (9) days.

In addition to monitoring optimal WQP values, our water system routinely monitors for lead and copper. The most recent monitoring conducted latest lead and copper monitoring period, i.e., July 1, 2025, to December 31, 2025, demonstrated we are in compliance with the Federal action levels for lead and copper. If there is a lead action level exceedance, you will be notified accordingly.

### What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. This violation does not mean there is confirmed lead and/or copper in your drinking water. However, since corrosion control treatment is used to protect residents from lead and copper potentially leaching from internal pipes and solder, it is important to be aware of the health effects of lead and copper and steps you may take to reduce your exposure.

- Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.
- Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal physician.

*If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about your drinking water.*

Typically, lead and/or copper enters drinking water by leaching from pipes and plumbing components in [homes and/or building(s)]. We [have treatment installed and/or receive treated water] to reduce the wearing away of lead and/or copper leaching from pipes and plumbing components into the water and optimal WQP values set to ensure effectiveness of the treatment. Failure to meet the set values requires us to evaluate the currently installed treatment and operation thereof and take actions necessary to meet the optimal WQP values.

## **What should I do?**

**You do not need to use an alternate water supply (e.g., bottled water).** However, if you have specific health concerns, consult your doctor. Additionally, if you would like to reduce your potential exposure to lead and/or copper in drinking water, you may choose to take the following steps:

- Run water to flush out lead and/or copper. Run water for 15 – 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking if it hasn't been used for several hours.
- Use cold water for cooking and preparing baby formula. Do not cook with or drink water from the hot water tap, Lead dissolves more quickly into hot water. Do not use water from the hot water tap to make baby formula.
- Do not boil water. Boiling water will not reduce lead and/or copper levels.
- Regularly remove and clean aerators/screens on plumbing fixtures. Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

*For additional steps you may take to reduce your exposure to lead in drinking water, see <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>.*

## **What is being done?**

Woodland Park Water Department is required to keep their orthophosphate at a 0.3 or higher at the point of entry. We anticipate resolving the problem within three months. We have developed a program to more closely monitor the orthophosphate of the drinking water we receive from Passaic Valley Water Commission. All samples in the new monitoring period, which started in January 2026, have all been within the acceptable range.

For more information, please contact Anthony Laguerra or Matthew Mulroony at 973-256-1264.

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

This notice is being sent to you by Woodland Park Water Department. State Water System ID#:NJ1616001.

Date distributed: 4/20/26.